

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7260-1508:0500

CATEGORY: Smoke Detection System-Beam Type

LISTEE: FFE, Ltd., 9 HUNTING GATE HITCHIN, HERTFORDSHIRE, England SG4 0TJ United Kingdom
Contact: Nerina Walton +44 (0)1462 444 740
Email: nerina.walton@ffeuk.com

DESIGN: Model Fireray One Projected Beam Smoke Detector. Unit consist of an integrated controller, transmitting and receiving detector, and reflector. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 14 - 36 VDC
5.5 mA Standby\Alarm current

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as projected beam smoke detection systems for use with separately listed compatible fire alarm control units. Authority having jurisdiction should be consulted prior to installation. Refer to listee's Installation Instruction Manual for details.

09-07-2018 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**

Fire Engineering Division